

EC-TYPE EXAMINATION CERTIFICATE (MODULE B)

Certificate No:
MEDB00008DC

Application of: Directive 2014/90/EU of 23 July 2014 on marine equipment (MED), issued as "Forskrift om Skipsutstyr" by the Norwegian Maritime Authority. This Certificate is issued by DNV AS under the authority of the Government of Norway.

This is to certify:

That the A & B Class divisions fire integrity: A class divisions.

with type designation(s)
Weber Marine A-60 Floor N Light

Issued to
SAINT-GOBAIN BYGGEVARER AS
Oslo, Norway

is found to comply with the requirements in the following Regulations/Standards:
Regulation (EU) 2022/1157,
item No. MED/3.11a. SOLAS 74 as amended, Regulation II-2/3.2 & II-2/9, IMO 2010 FTP Code, IMO MSC/Circ.1120 and IMO MSC.1/Circ.1434,1435; IMO MSC.1/Circ.1616, 1621


Further details of the equipment and conditions for certification are given overleaf.

This Certificate is valid until **2028-08-17**.

Issued at **Høvik** on **2023-08-18**

DNV local unit:
East & South Norway CMC

Approval Engineer:
Thorvald Furuseth



Notified Body
No.: **0575**

for **DNV AS**

.....
Sverre Olav Bergli
Head of Notified Body

A U.S. Coast Guard approval number will be assigned to the equipment when the production module has been completed and will appear on the production module certificate (module D, E or F), as allowed by the "Agreement between the United States of America and the EEA EFTA states on the mutual recognition of Certificates of Conformity for Marine Equipment" signed 17 October 2005, and amended by Decision No 1/2019 dated February 22nd, 2019.



The mark of conformity may only be affixed to the above type approved equipment and a Manufacturer's Declaration of Conformity issued when the production-surveillance module (D, E or F) of Annex B of the MED is fully complied with and controlled by a written inspection agreement with a Notified Body. The product liability rests with the manufacturer or his representative in accordance with Directive 2014/90/EU.

This certificate is valid for equipment, which is conform to the approved type. The manufacturer shall inform DNV AS of any changes to the approved equipment. This certificate remains valid unless suspended, withdrawn, recalled or cancelled.

Should the specified regulations or standards be amended during the validity of this certificate, the product is to be re-approved before being placed on board a vessel to which the amended regulations or standards apply.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Product description

“Weber Marine A-60 Floor N Light”

Composed of structural steel deck insulated on the top side as follows (seen from deck and upwards):

Variant I:

1. Min. 20 mm “Isover U SeaProtect Slab 90” mineral wool, nominal density 90 kg/m³.
2. Woven glass fibre fabric of type “US style 7628” from P-D Interglas Technologies Ltd., or equivalent approved product.
3. min. 25 mm weberfloor 4660N Marine Elastic, cement based levelling compound with nominal density of 1.7kg/m²/mm, or the following alternative solutions:
 - min. 25 mm weberfloor 4670N Marine Base, cement based levelling compound with a nominal density of 1.8 kg/m²/mm.

Variant II:

1. 1-2 mm thick Viscoelastic layer “Weber Marine VEM PU-1 (density 1.34 kg/m³)
2. min. 5mm weberfloor 4660N Marine Elastic levelling compound, cement based, fibre-reinforced levelling compound with nominal density of 1.78 kg/m²/mm, or the following alternatives:
 - weberfloor 4670N Marine Base, cement based levelling compound with a nominal density of 1,8 kg/m²/mm.
 - weberfloor 4680N Marine Light, cement based levelling compound with a nominal density of 0,9 kg/m²/mm.
 - weberfloor 4686N Marine Extra Light, cement based levelling compound with a nominal density of 0,65 kg/m²/mm.
 - weberfloor 4690N Marine Combi, cement based levelling compound with a nominal density of 1,55 kg/m²/mm.
 - 1 mm – 4mm thick steel plates/tiles.
3. Min. 20 mm “Isover U SeaProtect Slab 90” mineral wool, nominal density 90 kg/m³.
4. Woven glass fibre fabric of type “US style 7628” from P-D Interglas Technologies Ltd., or equivalent approved product.
5. min. 25 mm weberfloor 4660N Marine Elastic, cement based levelling compound with nominal density of 1.7kg/m²/mm, or the following alternative solutions:
 - min. 25 mm weberfloor 4670N Marine Base, cement based levelling compound with a nominal density of 1.8 kg/m²/mm.

Variant III:

Composed of layer 2, 3, 4, 5 as mentioned in Variant II.

The cement in layer 3 (Variant I) & layer 5 (Variant II & III) is reinforced with Ø5mm steel grid (150 mm x 150 mm).

Application/Limitation

Approved for use as a horizontal fire retarding division of class A-60.

The insulation materials, adhesives and vapour barriers used have to be approved according to the Marine Equipment Directive and bear the Mark of Conformity. This requirement may also be applicable for surface materials used, if required by relevant rules and regulations.

Each product is to be supplied with its manual for installation, use and maintenance.

Type Examination documentation

Test report No. 150070-32 dated 8 August 2023 from RISE, Trondheim, Norway.

Assessment report No. 150101-59 dated 3 February 2022 from RISE, Trondheim, Norway.

Tests carried out

Tested according to IMO 2010 FTP Code Part 3.

Marking of product

The product is to be marked with name and address of manufacturer, type designation, fire technical rating, the MED Mark of Conformity and USCG Approval Number if applicable (see first page).